

Mandatory Public Notification Language

Notice of Drinking Water Treatment Technique Violation(s)

STAFF WSC LACASA AREA TX0670033 has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. During JUNE, JULY, AUGUST, and SEPTEMBER, 2025, sufficient levels of chlorine residual were not met in more than five percent (5%) of the monthly samples.

The following actions are being taken to address this issue:

Writing a “standard operating procedure” for flushing of dead-end lines to ensure that proper testing procedures are defined and that each operator has a copy of that procedure.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Linda Meroney at Staff WSC at 254-647-5133 or 254-433-9452.